



File: ULC Subject C107.21
ULC-G5.2
CCF 7
TSS 7

December 17, 2013

CERTIFICATION BULLETIN 2013-17

ULC/ORD-C107.21-92, 1ST Edition of the Other Recognized Document for Under Dispenser Sumps

To: Subscribers to ULC's Certification Service for Under Dispenser Sumps in accordance with ULC/ORD-C107.21-92 and Others Interested.

- EGYIC – Under Dispenser Sumps and Underground Tank Risers

The requirements in the current edition of ULC/ORD-C107.21 require sumps made from steel to be coated with a compound conforming to the requirements of ULC-S616M, Standard for The Testing of Liquid Protective Coating Materials as required by ULC-S603.1 for use in Connection with the Corrosion Protection of Underground Tanks.

ULC-S616 was superseded when the coating testing requirements were added to the 3rd Edition of CAN/ULC-S603.1 under Part 1.

Since this was not covered by a file review at that time we will be reviewing our files to ensure current listed products are in compliance to the coating requirements now contained in CAN/ULC-S603.1, 4th Edition, Section 5.

The effective date, for currently Listed products to comply with the new and/or revised coating requirements, will be **June 30, 2014**.

Any questions concerning the above should be directed to Mr. Gunsimar Paintal by email @ Gunsimar.Paintal@ul.com.

Sincerely,

Underwriters Laboratories of Canada Inc.

A handwritten signature in black ink, appearing to read 'G. Paintal', written over a horizontal line.

Gunsimar Paintal

Regional Manager – Accreditation & Quality
International Certification Manager – NCB UL(CA)
ULC Mark Program Owner