



Subject File 1500  
ULC/ORD-C2775

December 1, 2009

**CERTIFICATION BULLETIN NO. 2009-30**

To: Members of the Advisory Council of the Underwriters Laboratories of Canada  
Others Interested

Subject: First Draft, Proposed First Edition, ULC/ORD-C2775, Fixed Condensed Aerosol Extinguishing System Units

Attached is a copy of the First Draft, Proposed First Edition, ULC/ORD-C2775, Fixed Condensed Aerosol Extinguishing System Units, for your review, comment and Ballot. **Ballots are for response by ULC Advisory Council Members only.**

This ORD covers the construction and operation of fixed condensed aerosol fire extinguishing system units and automatic units for total flooding applications intended to be installed, inspected, tested, and maintained in accordance with the Standard for Fixed Aerosol Fire Extinguishing Systems, NFPA 2010.

This ORD also cover fixed condensed aerosol automatic extinguisher units that do not have a manual means of operation, and are intended to be used in accordance with the manufacturer's installation instructions. Automatic units are not intended: for use as a general substitute for aerosol generating extinguishing system units; or for protection of fire risks larger than those specified in the manufacturer's instructions for a single unit by using multiple units.

Please return your Ballots prior to January 15, 2010.

**Ballots are to be completed on the attached Form and submitted by e-mail to:**  
[Graham.r.Dulmage@ca.ul.com](mailto:Graham.r.Dulmage@ca.ul.com)

UNDERWRITERS LABORATORIES OF CANADA

Gunsimar Paintal,  
Regional Quality Manager and ULC Mark Program Owner

Please return to:

Rae Dulmage  
Underwriters Laboratories of Canada  
200-440 Laurier Ave W  
Ottawa, ON K1R 7X6  
Tel: 613-755-2729 Ext. 6229  
Fax: 613-231-5977  
Graham.r.Dulmage@ca.ul.com

**IMPORTANT:**

YOUR RETURN OF  
THIS BALLOT IS  
ESSENTIAL TO THE  
FUNCTIONING OF THE  
ULC ADVISORY COUNCIL  
PROCESS

## **BALLOT**

***(to be returned by January 15, 2010)***

With respect to the Bulletin dated December 1, 2009 on the First Draft, proposed First Edition, ULC/ORD-C2775, *Fixed Condensed Aerosol Extinction Measuring System Units*:

1. We agree with the First Draft, proposed First Edition, ULC/ORD-C2775,
2. We agree with the First Draft, proposed First Edition, ULC/ORD-C2775, except for the following: **(LIST BELOW)**
3. We believe the First Draft, proposed First Edition, ULC/ORD-C2775, is inappropriate for the following reasons: **(LIST BELOW)**
4. We wish to abstain from voting on this item.

Comments:

---

---

---

---

Signature: \_\_\_\_\_

Company/Organization: \_\_\_\_\_

Name of Member: \_\_\_\_\_

Title: \_\_\_\_\_

BALLOT FOR ULC ADVISORY COUNCIL MEMBERS ONLY